

# 2019 Consumer Confidence Report

Water System Name: City of Portola

Report Date: 29.June.2020

*We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2018 and may include earlier monitoring data.*

**Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.**

Type of water source(s) in use: In 2019, groundwater from springs and surface water from Lake Davis.

Name & general location of source(s): During 2019, the water for the city came from Willow Springs and the Lake Davis Water Treatment Plant.

Drinking Water Source Assessment information: An assessment was completed between July 2002 and August 2003. A copy can be obtained by calling the Department of Public Health at (530) 224-4800. The Commercial Street Well was found to be the most vulnerable to the following activities associated with detected contaminants: contractor or government agencies equipment storage yard: sewer collection system. Our sources were found to be the most vulnerable to the following activities not associated with any detected contaminants: Managed Forests, Photo processing/ printing: railroad yard/ maintenance/ fueling areas; utility stations-maintenance areas.

Time and place of regularly scheduled board meetings for public participation: Second and Fourth Wednesday of every month.

For more information, contact: Todd Roberts Phone: ( 530 ) 832-6809

## TERMS USED IN THIS REPORT

**Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

**Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

**Public Health Goal (PHG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

**Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Primary Drinking Water Standards (PDWS):** MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

**Secondary Drinking Water Standards (SDWS):** MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

**Treatment Technique (TT):** A required process intended to reduce the level of a contaminant in drinking water.

**Regulatory Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

**Variances and Exemptions:** State Board permission to exceed an MCL or not comply with a treatment technique under certain conditions.

**ND:** not detectable at testing limit

**ppm:** parts per million or milligrams per liter (mg/L)

**ppb:** parts per billion or micrograms per liter (µg/L)

**ppt:** parts per trillion or nanograms per liter (ng/L)

**ppq:** parts per quadrillion or picogram per liter (pg/L)

**pCi/L:** picocuries per liter (a measure of radiation)

**The sources of drinking water** (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

**Contaminants that may be present in source water include:**

- *Microbial contaminants*, such as viruses and bacteria that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides* that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants* that can be naturally-occurring or be the result of oil and gas production and mining activities.

**In order to ensure that tap water is safe to drink**, the USEPA and the State Water Resources Control Board (State Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

**Tables 1, 2, 3, 4, 5, 7, and 8 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent.** The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

**TABLE 1 – SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA**

| Microbiological Contaminants<br>(complete if bacteria detected) | Highest No. of<br>Detections | No. of months in<br>violation | MCL                                                                                                                        | MCLG | Typical Source of Bacteria           |
|-----------------------------------------------------------------|------------------------------|-------------------------------|----------------------------------------------------------------------------------------------------------------------------|------|--------------------------------------|
| Total Coliform Bacteria                                         | (In a mo.)                   | 0                             | More than 1 sample in a month with a detection                                                                             | 0    | Naturally present in the environment |
| Fecal Coliform or <i>E. coli</i>                                | (In the year)                | 0                             | A routine sample and a repeat sample detect total coliform and either sample also detects fecal coliform or <i>E. coli</i> | 0    | Human and animal fecal waste         |

**TABLE 2 – SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER**

| Lead and Copper<br>(complete if lead or copper detected in the last sample set) | Sample Date | No. of samples collected | 90 <sup>th</sup> percentile level detected | No. sites exceeding AL | AL  | PHG | Typical Source of Contaminant                                                                                                 |
|---------------------------------------------------------------------------------|-------------|--------------------------|--------------------------------------------|------------------------|-----|-----|-------------------------------------------------------------------------------------------------------------------------------|
| Lead (ppb)                                                                      | 9/28/2017   | 10                       | .001                                       | 0                      | 15  | 0.2 | Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits |
| Copper (ppm)                                                                    | 9/28/2017   | 10                       | 0.15                                       | 0                      | 1.3 | 0.3 | Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives               |

**TABLE 3 – SAMPLING RESULTS FOR SODIUM AND HARDNESS**

| Chemical or Constituent<br>(and reporting units) | Sample Date | Level Detected | Range of Detections | MCL  | PHG (MCLG) | Typical Source of Contaminant                                  |
|--------------------------------------------------|-------------|----------------|---------------------|------|------------|----------------------------------------------------------------|
| Sodium (ppm)                                     | 2014-2016   | 48             | 5.6 - 48            | none | none       | Salt present in the water and is generally naturally occurring |
| Hardness (ppm)                                   | 2014-       | 69             | 29 - 69             | none | none       | Sum of polyvalent cations present                              |

|  |      |  |  |  |  |                                                                                    |
|--|------|--|--|--|--|------------------------------------------------------------------------------------|
|  | 2016 |  |  |  |  | in the water, generally magnesium and calcium, and are usually naturally occurring |
|--|------|--|--|--|--|------------------------------------------------------------------------------------|

\*Any violation of an MCL or AL is asterisked. Additional information regarding the violation is provided later in this report.

**TABLE 4 – DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD**

| Chemical or Constituent<br>(and reporting units) | Sample Date | Level Detected | Range of Detections | MCL [MRDL] | PHG (MCLG) [MRDLG] | Typical Source of Contaminant                                                                    |
|--------------------------------------------------|-------------|----------------|---------------------|------------|--------------------|--------------------------------------------------------------------------------------------------|
| Barium (ppm)                                     | 2014-2015   | 0.016          | 0.016               | 2.0        | 2.0                | Erosion of natural deposits; discharge from metal refineries                                     |
| Nitrate (ppm)                                    | 2016        | < 0.065        | < 0.05 - .08        | 10         | 10                 | Runoff and leaching from fertilizer use; leaching from septic tanks, sewage and natural deposits |
| Gross Alpha (pCi/L)                              | 2015        | 2.36           | 1.2 – 2.98          | 15         | 0                  | Erosion of natural deposits                                                                      |
| Radium 228 (pCi/L)                               | 2015        | 0.904          | 0.704 - 0.732       | 5          | 0                  | Erosion of natural deposits                                                                      |
| Haloacetic Acids (ppb)<br>HAA5                   | 2019        | 14.00          | 4.00 – 22.00        | 60         |                    | Byproduct of drinking water disinfection                                                         |
| Total Trihalomethanes<br>TTHM (ppb)              | 2019        | 14.90          | 9.60 – 22.00        | 80         |                    | Byproduct of drinking water disinfection                                                         |

**TABLE 5 – DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD**

| Chemical or Constituent<br>(and reporting units) | Sample Date | Level Detected | Range of Detections | MCL  | PHG (MCLG) | Typical Source of Contaminant                             |
|--------------------------------------------------|-------------|----------------|---------------------|------|------------|-----------------------------------------------------------|
| Chloride (ppm)                                   | 2014-2015   | 6.3            | 0.6 - 15            | 500  | ---        | Runoff leaching from natural deposits; seawater influence |
| Iron (ppb)                                       | 2014-2015   | 173            | ND - 520            | 300* | ---        | Leaching from natural deposits; industrial waste          |
| Total Dissolved Solids (ppm)                     | 2014-2015   | 200            |                     | 1000 | ---        | Runoff/ Leaching from natural deposits                    |
| Zinc (ppb)                                       | 2014-2015   | 6.7            | ND - 20             | 5000 | ---        | Runoff/ leaching from natural deposits; industrial waste  |

### Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

**Lead-Specific Language for Community Water Systems:** If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of Portola is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has

been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

### For Systems Providing Surface Water as a Source of Drinking Water

| TABLE 8 - SAMPLING RESULTS SHOWING TREATMENT OF SURFACE WATER SOURCES                                    |                                                                                                                                                                                                                     |
|----------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Treatment Technique <sup>(a)</sup><br>(Type of approved filtration technology used)                      | Membrane Filtration                                                                                                                                                                                                 |
| Turbidity Performance Standards <sup>(b)</sup><br>(that must be met through the water treatment process) | Turbidity of the filtered water must:<br>1 – Be less than or equal to .1 NTU in 95% of measurements in a month.<br>2 – Not exceed 1 NTU for more than eight consecutive hours.<br>3 – Not exceed 1 NTU at any time. |
| Lowest monthly percentage of samples that met Turbidity Performance Standard No. 1.                      | 100%                                                                                                                                                                                                                |
| Highest single turbidity measurement during the year                                                     | 0.200 NTU                                                                                                                                                                                                           |
| Number of violations of any surface water treatment requirements                                         | 0                                                                                                                                                                                                                   |

(a) A required process intended to reduce the level of a contaminant in drinking water.

(b) Turbidity (measured in NTU) is a measurement of the cloudiness of water and is a good indicator of water quality and filtration performance. Turbidity results which meet performance standards are considered to be in compliance with filtration requirements.

### Summary Information for Operating Under a Variance or Exemption

N/A